

Flame Certificate

Aalto = Wave

082330

AiNO[®]

Plaster (ground) was tested and met the following flammability requirements:

FLAMMABILITY:

ASTM-E84 Tunnel Test Passed Class A
EU Class Flame (EN15102) Passed Class B, s2
BS476 Parts 6&7 Passed all requirements
CAN/ULC-S102 Passed all requirements

Contact hello@shopaino.com with any questions.